

United Kingdom

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com				
Certificate No.:	IECEx EXV 19.0061X	Page 1 of 4	Certificate history:	
Status:	Current	Issue No: 0		
Date of Issue:	2019-11-25			
Applicant:	Newson Gale Limited Omega House Private Road 8 Colwick Nottingham NG4 2JX United Kingdom			
Equipment:	Bond-Rite REMOTE			
Optional accessory:				
Type of Protection:	Intrinsic Safety, Protection by Er	nclosure		
Marking:	Ex ia IIC T4 Ga Ex ta IIIC T135°C Da Ta = -40°C to +60°C			
Approved for issue of Certification Body:	on behalf of the IECEx	Sean Clarke CEng MSc FIET		
Position:		Certification Manager		
Signature: (for printed version)				
Date:				
 This certificate a This certificate is The Status and a 	nd schedule may only be reproduced s not transferable and remains the pro authenticity of this certificate may be v	in full. perty of the issuing body. rerified by visiting www.iecex.com or use of this QR Code.		
Certificate issued	d by:			
ExVeritas Limit Units 16-18 Abe Wrexham Ind. E Wrexham LL 13	ed enbury Way Est. 9UZ	ExVe	eritas®	



IECEx Certificate of Conformity

Certificate No.:	IECEx EXV 19.0061X	Page 2 of 4		
Date of issue:	2019-11-25	Issue No: 0		
Manufacturer:	Newson Gale Limited Omega House Private Road 8 Colwick Nottingham NG4 2JX United Kingdom			
Additional manufacturing locations:				
This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended				
STANDARDS : The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards				
IEC 60079-0:2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirer	nents		
IEC 60079-11:2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intr	insic safety "i"		
IEC 60079-31:2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition prot	ection by enclosure "t"		
	This Certificate does not indicate compliance with safety ar other than those expressly included in the Stand	nd performance requirements lards listed above.		
TEST & ASSESSMENT REPORTS: A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:				
Test Report:				

GB/EXV/ExTR19.0065/00

Quality Assessment Report:

GB/EXV/QAR19.0009/00



IECEx Certificate of Conformity

Certificate No.: IECEx EXV 19.0061X

Page 3 of 4

Date of issue: 2019-11-25

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Bond-Rite REMOTE provides an intrinsically safe output to a clamp, which is connected to the equipment via a bonding cable. The equipment is designed to be used with all types of metallic plant such as drums, road and rail tankers, IBCs, mixing vessels and other similar applications. Connection of the clamp prevents a dangerous build up of static charge during transfer, handling or mixing operations, enabling it to 'bleed' safely to earth. Its use assumes that no charge is present prior to the clamp being attached. The Bond-Rite REMOTE provides an indication that the resistance between clamp and the plant to which it is attached is less than 10 ohms. Under these circumstances, an LED on the cover will be illuminated. A loop connection to earth also ensures that the item of plant is connected to earth.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1.	1. The replacement battery shall be one of the following types only:				
•	Ultralife type U9VL-J				
•	Varta type 6122				
The batt	se batteries are intrinsically safe and may be replaced when the equipment is in a hazardous area. The ery must be removed when the equipment is externally powered				
2.	The number of Bond-Rite REMOTE units that can be connected to the power supply with an output voltage (Uo) not exceeding 9.0 V depends on the following	;			
•	External capacitance of the power supply, Co(P/S)				
•	External inductance of the power supply, Lo(P/S)				
•	Total capacitance of all the cables between the power supply and the connected Bond-Rite REMOTE units, C cable				
•	Total inductance of all the cables between the power supply and the connected Bond-Rite REMOTE units, L cable				
In the system comprising a single power supply and multiple Bond-Rite REMOTE units, Ccable must not exceed Co(P/S) and Lcable must not exceed Lo(P/S)					



IECEx Certificate of Conformity

Certificate No.: IECEx EXV 19.0061X

Page 4 of 4

Date of issue:

2019-11-25

Issue No: 0

Additional information:

The Bond-Rite REMOTE has two power options: it is either powered by an internal battery or is supplied from an external Newson Gale power supply unit (ER UPS). The safety description of the Bond-Rite REMOTE is as follows:

Power supply input (for units without the battery fitted)					
Ui	=	9.0 Vdc	Uo	=	11.1 V
Ci	=	0	lo	=	0.143 A
Li	=	0	Po	=	0.26 W
			Со	=	0.9 μF
			Lo	=	1734 μΗ

Conditions of Manufacture

The Manufacturer shall comply with the following condition of manufacture:

1.	The Bond-Rite REMOTE incorporates previously-certified enclosures as listed below. It is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with these devices, and the manufacturer shall inform Sira of any modifications of the devices that may impinge upon the explosion safety design of their products.			
	Certificate number	Details		
	IECEx PTB 08.0003U,	ROSE Systemtechnik type 26 enclosure		
	IECEx PTB 07.0059U,	ROSE Systemtechnik type 35 enclosure (s/s)		
2.	Each manufactured sample of the Bond-Rite REMOTE with a stainless steel enclosure shall be subjected to an electric strength test using a test voltage of 500 Vac applied between the circuit and enclosure for 60 s. Alternatively, a voltage of 20% higher may be applied for 1 s. There shall be no evidence of flashover or breakdown and the maximum current flowing shall not exceed 5 mA			

Annex:

EXV 19.0061X Annex 0.pdf

Annex to: IECEx EXV 19.0061X Issue 0



Manufacturer's documents:				
Drawing No.:	Rev.	Title:	Date:	
AA0204R1A-CERT	А	Bond-Rite II	07/02/2011	
AA0204R1A-PLC	А	Bond-Rite II Certified Parts List	07/02/2011	
AA0204R1A-CB-CERT	А	Bond-Rite II Board PCB Layout	07/02/2011	
AA0204R1A-CT-CERT	А	Bond-Rite II Board PCB Layout	07/02/2011	
AA0204R1A-SS-CERT	А	Bond-Rite II Board PCB Layout	07/02/2011	
B-RR-2011 GA	2A	Bond-Rite Remote Using GRP or	11/07/2012	
		Stainless Steel Enclosure		
BRR LAB 1	AG	Certification Detail Bond-Rite Remote	21/10/2019	